# MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY CCR CERTIFICATION CALENDAR YEAR 2016

### 200006

	300006
	Public Water Supply Name
	City of Pascagoula
	List PWS ID #s for all Community Water Systems included in this CCR
Custo	Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a umer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the mers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax of La copy of the CCR and Certification to MSDH, Please check all boxes that apply.
X	Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
	Advertisement in local paper (attach copy of advertisement)  On water bills (attach copy of bill)  Email message (MUST Email the message to the address below)  Other
	Date(s) customers were informed:05/25/2017, / 06/26/2017_
×	CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Hand delivery to customers missed on water bills.
	Date Mailed/Distributed: <u>O6 /29 / 2017</u>
	CCR was distributed by Email (MUST Email MSDH a copy)  As a URL (Provide URL  As an attachment  As text within the body of the email message
	CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
	Name of Newspaper:
	Date Published:/
X	CCR was posted in public places. (Attach list of locations)  Date Posted: 05 / 11 /2017
X	CCR was posted on a publicly accessible internet site at the following address ( <b>DIRECT URL REOUIRED</b> ):
	www.cityofpascagoula.com/ccr
I here public the Sl the w	Ely certify that the 2016 Consumer Confidence Report (CCR) has been distributed to the customers of this c water system in the form and manner identified above and that I used distribution methods allowed by DWA. I further certify that the information included in this CCR is true and correct and is consistent with vater quality monitoring data provided to the public water system officials by the Mississippi State retment of Health, Bureau of Public Water Supply.
On l Name	White (President, Mayor, Owner, etc.)  O6/28/2017  Date

Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

May be faxed to: (601)576-7800

May be emailed to: water.reports@msdh.ms.gov

# **CCR Locations**

- 1. City Hall
- 2. Public Utilities
- 3. Code Enforcement
- 4. Public Works
- 5. Communy Water Plant
- 6. B-C Water Plant
- 7. Criswell Water Plant



# **UTILITY BILL**

Remit Copy

Please write your account number on your check and enclose this portion of bill with your payment. Make checks payable to: Pascagoula Utilities

Bill Number	Account Number	Customer #	Due Date :	Prev. Balance	Current Charges	Total Due
1875384	1363120000	17246	07/05/2017	.00	96.30	\$96.30
	·			If paying after Due C	Date pay this amount	Lete Payment \$96.30
	PLEASE DONAT	E TO HELP PASCAGOU	LA'S ELDERLY WITH	I UTILITY NEEDS	<b>→</b>	
	******AUTO**SCH 5-DI HUTCHISON JEFF	GIT 39567	382	<u>TO</u>	TAL REMITTED	
I	1602 WILLIAMS ST PASCAGOULA MS 395	676571		Name	ress corrections below:	
!	րկլիներուսույիություն	հրմիդիֆիիիիիինիիսիիի		Street ——————————————————————————————————	State _	Zip

0000604201720187538480000096305

Mississippi's Planskip City	
Pascagoula	

#### Pascagoula Utilities

P.O. Drawer 908

Pascagoula, MS 39568-0908 Telephone: (228) 938-6633

# **UTILITY BILL**

**Customer Copy** 

Keep this portion for your records

	Customer HUTCHISON JEFF	:		Service Address 1602 WILLIAMS ST						
Bill Number 1875384	Account 13631	and the State of the second of	Customer # 17246		Bill Date 06/20/2017		ue Date 05/2017			
Description	Present Read Date	Previous Read Date	Present Me	ter Reading	Previous Meter Reading	Usaga	Charge			
WATER SEWER JCUA GARBAGE BOND DEBT	06/14/2017 06/14/2017 06/14/2017 06/16/2017 06/15/2017	05/16/2017 05/16/2017 05/16/2017 05/18/2017 05/18/2017		4697 0 0 0 0	4630 0 0 0 0	67 67 67 0 0	7 24.90 7 9.11 7 41.79 0 15.64			
TAX							.00			
· · · · · · · · · · · · · · · · · · ·			Prev.	Balance .00	Current Charges 96.30		Total Due \$96.30			

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER IS AVAILABLE IN THE 2017 CONSUMER CONFIDENCE REPORT AT WWW.CITYOFPASCAGOULA.COM/CCR. YOU MAY REQUEST A HARD COPY BY CALLING OUR OFFICE AT 228-938-6623

DELINQUENT ACCOUNTS

IF ANY PORTION OF THIS BILL IS UNPAID AFTER THIRTY DAYS FROM THE BILLING DATE, YOUR WATER AND/OR GAS SERVICE MAY BE CUT OFF WITHOUT ANY FURTHER NOTIFICATION FROM THIS OFFICE.

IF YOUR SERVICE IS CUT OFF FOR NON PAYMENT, THE UNPAID BAL-ANCE MUST BE PAID IN FULL TO RECONNECT. A TRIP CHARGE OF \$16.05 WILL BE ADDED ON YOUR NEXT UTILITY BILLING FOR EACH TRIP MADE TO THE PREMISE. OUR EMPLOYEES ARE PROHIBITED FROM TURNING ON GAS OR WATER SERVICE AT ANY LOCATION WITHOUT THE PRESENCE OF THE CUSTOMER OR ANOTHER ADULT GIVEN ACCESS TO THE PREMISES BY THE CUSTOMER.

THESE FEES ARE CURRENT AS OF JANUARY 31,2003. THEY ARE SUBJECT TO CHANGE WITHOUT FURTHER NOTICE, FOR A CURRENT LIST OF THESE FEES CALL OUR OFFICE AT 938-6633.

For all correspondence or payment in person:

Pascagoula Utilities 622 Delmas Avenue Pascagoula,MS 39567 Telephone: (228) 938-6633

Office Hours: 8.00AM to 5:00PM Monday through Friday
Except on Holidays

#### DISPUTES AND CORRECTIONS

IF YOU HAVE A DISPUTE CONCERNING YOUR BILL, YOU ARE ENTITLED TO BE HEARD ABOUT THE MATTER AT THE UTILITY ACCOUNTING OFFICE. AT YOUR REQUEST YOU WILL BE GRANTED AN ADMINISTRATIVE REVIEW AND YOU WILL BE ALLOWED TO SEE YOUR RELEVANT ACCOUNT RECORDS.

## Water Quality Report

#### For The City of Pascagoula

ID # 300006

We are pleased to present to you our Annual Water Quality Report for the year 2016. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. In view of this goal, we are pleased to report that our drinking water meets all federal and state requirements.

Our water comes from wells drilled deep into aquifers 300 to 800 feet below the surface. These aquifers are the Pascagoula and the Graham's Ferry formations. Each well is evaluated on an annual basis for purity and content. The City of Pascagoula uses a Reverse Osmosis/Ozone water filtration system to purify the well water. If you want to learn more about your water and how the City of Pascagoula works to keep your water safe please contact Jeff Hutchison (228) 938-6623, Water Superintendent, at our 14th St. offices between 7:00 a.m. and 3:30 p.m. or write to us at P.O. Drawer 908, Pascagoula, MS 39568-0908. Our City Council meets on the first and third Tuesday of each month at 6:00 p.m. at City Hall. Information is also available on our website <a href="https://www.cityofpascagoula.com">www.cityofpascagoula.com</a>

The source water assessment has also been completed for our public water system to determine the overall susceptibility of its drinking water to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our Public Works Department and is available for viewing at our office upon request.

The City of Pascagoula routinely monitors for substances and contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it may pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, is suspected to contain small amounts of some substances or contaminants. It is important to remember that the presence of these substances or contaminants does not necessarily pose a health risk.

In this table, you will find many terms and abbreviations you might not be familiar with. To help you understand these terms; we have provided the following definitions: Unregulated Contaminant Monitoring (UMCR)

Running Annual Average (RAA)

Maximum Residual Disinfectant Levels (MRDL) the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND) - laboratory analysis indicates that substances or contaminants are not present. Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter ug/L - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/I) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/I) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

 ${\it Million \ Fibers \ per \ Liter \ (MFL)}$  - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Minimum Reporting Level (MRL)

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow:

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water. Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

				TEST RESU				
Contaminant	Violation Y/N	Date Collected	Your Water	Range of Detects or # of Samples Exceeding MCL/ACL		MCLG	MCL	Likely Source of Contamination
Volatile Organic Co		08/12/14	1.4	0.506-1.4	Ppb	10	10000	Discharge from petroleum
Xylenes, Total	N	10/17/14	0.506	0.506-1.4	rpb	10	10000	factories; Discharge from chemical factories
Inorganic Contamir	ants						<u> </u>	
Chromium		04/10/15	0.0012	0.0006-	Mg/l	100	0.1	Discharge from steel and
Chronium	1	04/10/15	0.0006	0.0012				pulp mills; erosion of natural deposits
Fluoride		04/10/15 04/10/15 04/10/15	1.02 0.937 0.815	0.815-1.02	Mg/l	4	4	Erosion of natural deposits water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Barium		04/10/15 04/10/15 04/03/15	0.0047 0.0011 0.00276	0.0011- 0.00276	Mg/l		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Disinfection By-Pro	ducts							
Chlorine	N	01/01/16 12/31/16	1.00 (RAA)	0.20/1.43 (MRDL)	Mg/l		4	Water Additive used to control microbes.
ТНМ	N	01/01/16 12/31/16	5.79 (RAA)	1.63-13.57	Ppb	0	80	By-product of drinking water chlorination
HAA5	N	01/01/16 12/31/16	2.33 (RAA)	1.0-4.0	Ppb		60	Byproduct of drinking water disinfection
Bromate	N	08/05/13 08/05/13	0.008 0.008		Mg/l		0.010	Byproduct of drinking water disinfection
Lead & Copper		<u> </u>	<u> </u>	J		L	l	
Lead	N	07/27/16	2 (90th)		Ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Copper	N	07/27/16	0.3 (90th)		Mg/l	1.3	АЬ=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Additional Monitorii	ig (UCMR 3)				<u></u>	•	A	
Chloromethane	N	02/19/14	0.37	0.37	Ug/l		MRL 0.20	Halogenated alkane; used as foaming agent, in production of other substances, and byproduct that can form when chlorine is used to disinfect drinking water

Strontium	N	02/20/14	1.1	1.1-8.5	Ug/l	MRL	Naturally-occurring
		02/20/14	8.5			0.30	element; historically,
							commercial use of
							strontium has been in
							faceplate glass of
							cathode-ray tube
							televisions to block x-ray
							emissions
Vanadium	N	08/30/13	0.21	0.21	Ug/l	MRL	Naturally-occurring
		4				0.20	element;
							Used as vanadium
					1		pentoxide which is a
							chemical intermediate
							and a catalyst
Hexavalent Chromium	N	02/20/14	0.041	0.041	Ug/l	MRL	Naturally-occurring
						0.030	element;
							Used in making steel and
							other alloys. Chromium-3
							or -6 forms are used for
							chrome plating, dyes and
•					1	ĺ	pigments, leather tanning
Chromium	N	02/20/14	0.073	0.073	II/1	MRL	and wood preservation.
Omonium	14	02/20/14	0.013	0.013	Ug/l	0.067	Discharge from steel and
						0.061	pulp mills; erosion of natural deposits.
		1	l	<u> </u>	<u> </u>	<u> </u>	natural deposits.

To comply with the "Regulation Governing Fluoridation of Community Water supplies", **City of Pascagoula** is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride results were within the optimal range of 0.7-1.3 was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 88%.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested by a private laboratory. Letting the water run for 30 seconds to 2 minutes before using tap water may reduce your exposure to lead. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791) <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>.

Some people who drink water-containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. People whose immune system is compromised such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from diseases. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium (bacteria more commonly found in surface water) and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If you want additional information about your drinking water, you may contact our certified waterworks operator or you may prefer to log on to the Mississippi Department of Health website and obtain specific information about your system and its compliance history at the following address: <a href="http://msdh.ms.gov/msdhsite/static/30,0,76.html">http://msdh.ms.gov/msdhsite/static/30,0,76.html</a> Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained.

Our water resources are the heart of our community, our way of life and our children's future. You can help us in our efforts to provide you with quality water and services by keeping alleys clear of debris, fences, and other obstructions, by protecting your water meter so that it may be read accurately, by preventing backflows and back siphons, by using pesticides wisely, and by not wasting this precious natural resource.